



ठाणे महानगरपालिका
THE MUNICIPAL CORPORATION OF THE CITY OF THANE
प्रदूषण नियंत्रण कक्ष
POLLUTION CONTROL CELL



E-mail : pcctmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखाडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas, Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 1364
Sample No.: P584

Date : 17 August 2023

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S PODAR INTERNATIONAL SCHOOL

Address : Rajlaxmi complex, Octroi naka, Pogaon, Near Chavindra, Bhiwandi- 421302

E_mail ID : adminassist.bhiwandi@podar.org ; admin.bhiwandi@podar.org

Date of receiving Sample : 14 August 2023

Sample Collected by : party

Type of Water Sample : Drinking water Sample

Parameters	Results	Limits as per IS 10500
pH	7.30	6.5 - 8.5
Free Residual Chlorine	Nil	1 ppm
Turbidity	2.0	5 NTU
Chloride	52.0	250 mg/L
Total Hardness	90.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

17-Aug-23

Prabhakar Sonawale

Thane Municipal Corporation, Thane

Authorised by

17-Aug-23

Omsatyashiv Paralkar

Thane Municipal Corporation, Thane

This is the analysis report of the Drinking water Sample Water sample received to our Vakratunda Laboratory on 14/8/2023. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000248/22-23 dated 08.12.2022

This Report has been Signature Digitally.

Principal
Podar International School
Bhiwandi.

Manager
Podar International School
Bhiwandi