

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(w/s) DIVISION



No-WS/LAB/1373/2022

Date- 1/10/2022

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME- Podar International School DATE OF EXAMINATION- 29/9/2022

ADDRESS- Chinchwad

SOURCE -

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coil	
1	water sample	Nil	0/100ml	-	potable
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS / LAB / 1377 / 2022

DATE - 01 / 10 / 2022

NAME - Podar International School

DATE OF RECEIPT - 29/09 / 2022

ADDRESS - chinchwad

DATE OF EXAMINATION - 29/9 / 2022

No.	Tests	I. S Standard for Drinking Water	Results mg/lit	Results mg/lit	Conclusion
1	Turbidity	5 N.T.U max	0.19 NTU	/	
2	pH	6.5 to 8.5	7.68		
3	Total Hardness (AS CaCo ₃)	300 mg/lit max	140 mg/lit		
4	Chloride	250 mg/lit max	44 mg/lit		
5	Calcium	75 mg/lit max	35.27 mg/lit		

NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY

COPY TO-


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44