

Date :-18/08/2023

To,

Principal

Podar International School Dhule

Gat No-304/2/2 Nagaon Budruk

Subject :- Santitary Condition Certificate

Reference :- 1) Your Official Letter dated 10/08/2023

This is to certify that an inspection team headed by health officer of Dhule Municipal Corporation Dhule inspected the Podar International School, Dhule Gat No.-304/2/2 Nagaon Budruk Mumbai agra National high way on dated 17-08-2023 and found that the Podar International School, Dhule has drinking water facilities for students and staff members of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Government of Maharashtra.

This Certificate is valid up to 31-07-2024


18/8/23
Medical Officer of Health
Dhule Municipal Corporation Dhule.



मुख्य अणुजीव शास्त्रज्ञ
जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, धुळे
देवपूर चर्च आवार, जयहिंद कॉलेजजवळ, धुळे - ४२४ ००२



महाराष्ट्रशासन

दूरध्वनी - कार्यालय :- (०२५६२) २९७४७३

Email : dphldhule@gmail.com

आरोग्य सेवा :

जा. क्र. मुअशा / जिसाआप्रशाधुळे / रासायनिक पाणी नमुने तपासणी
/ ५२/२०२३ दिनांक :- १२.०१.२०२३

Date of collection: --	Date of Receipt: 09/01/2023	Dt. Of analysis: 10/01/2023 onwards
------------------------	-----------------------------	-------------------------------------

SR. NO	TEST PARAMETER	Sample 1	Sample 2	Sample 3	BIS Specifications 10500 : 2012 Normal Values	
		Boar	RO		Desirable Limits	Permissible Limits
1	Physical Observations	Clear	Clear		--	--
2	Odour	Agreeable	Agreeable		Agreeable	Agreeable
3	Turbidity (N.T.U.)	0.14	0.11		1.0	5.0
4	pH Value	7.0	6.5		6.5 to 8.5	No Relaxation
5	Chlorides (as Cl)	66	24		250	1000
6	Nitrates (as NO ₃)	03	Nil		45	No Relaxation
7	Total Hardness (as CaCO ₃)	314	42		200	600
8	Alkalinity (as CaCO ₃)	302	28		200	600
9	Total Dissolved Solids	680	100		500	2000
10	Iron (as Fe)	Nil	Nil		1.0	No Relaxation
11	Fluoride (as F)	Nil	Nil		1	1.5

- 1) This Report is restricted only for the sample submitted to this laboratory
- 2) This sample is not collected by this Laboratory.

REMARKS

- A) Sample No.2 is chemically fit/potable for drinking purposes on the basis of analyzed parameters only. However, this water source(s) can be used for drinking purposes only after proper disinfection and ascertaining it's bacteriological quality.
- B) Sample No. 1 contains Total Hardness, Alkalinity and Total Dissolved Solids more than desirable limits but below permissible limit, hence it can be used in absence of alternate source and only after proper treatment & disinfection and ascertaining it's bacteriological quality.

Forwarded With Compliments
To : - Podar International School,
Gat No. 304/2/2. Near Nagaon Bari,
Mumbai-Agra National Highway,
Dhule 424005

With reference to letter no.- 2022-23/4423 Dated : -

(Prashant K Kulkarni)
Chief Bacteriologist,

Dist. Public Health Laboratory, DHULE

Fee : Rs.1200/- Receipt No. 5648707 Dt . 09/01/2023