



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:WBSES/D.O.Howrah/FP/216/14

Date: 03-09-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Podar International School Howrah. Lessor Mamraj Jayatri Foundation
Salap More, NH-6, Beside Kolkata West International City, Dist - Howrah, Pin-711403

Sub: Fire Safety Certificate for the occupancy of an existing construction of G+1 storied under group Educational building at the premises no.-Salap More, NH-6, beside Kolkata West International city, Dist.- Howrah, Pin - 711403.

This is in reference to your application no. G125189221300059 dated 23-05-2022 regarding the Fire Safety Certificate for the occupancy of an existing construction of G+1 storied under group Educational building at the premises no.-Salap More, NH-6, beside Kolkata West International city, Dist.- Howrah, Pin - 711403.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
3. The Interior finish decoration of building shall be made with low flame spread material confirming to the 1.8. Specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
6. A fire control room including a closed circuit TV system shall have to be installed which observe all the floors of the building.
7. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the Building.
8. Fire Licence shall have to be obtained for storing and processing with LPG and other highly combustible articles.
9. The employees and security staff shall be conversant with installed firefighting equipments of the building and to operate in the event of fire and testing.

10. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
11. Transformer and Switch Gears room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
12. All the pumps and detection systems which are incorporated in the building shall be kept in auto mode round the clock.
13. First Aid fire fighting system shall be provided as per I.S. specifications.
14. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
15. Periodical flashing of water in the Hydrants and sprinklers Pipe lines shall be made to maintain the efficient working performance of above mentioned system.
16. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

This Fire Safety Certificate is valid for Three years and has to be renewed every three year from the date of issue of this letter.

The certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature Not Verified
Digitally signed by ABHIJIT
PANDEY
Date: 2022.09.08 14:02:37 IST

Director
West Bengal Fire & Emergency Services



Principal
Podar International School
Howrah



MANAGER
Podar International School, Howrah
PODAR LITERACY & EDUCATION TRUST