

	नवी मुंबई महानगरपालिका	NaviMumbai MunicipalCorporation
	नमूमपा मुख्यालय, भु.क्र.1 व 2, किल्ले गावठाण जवळ, पामबीच जंक्शन, सेक्टर-15ए, सी.बी.डी., बेलापूर, नवी मुंबई-400614 दुरध्वनी क्र. : 27567130	NMMC Headquarter, Plot No.1 & 2, Near KilleGaonthan, Palmbeach Junction, Sector-15A, C.B.D., Belapur, Navi Mumbai - 400 614, TEL. No. : 2756 7130

No.NMMC/EE(Belapur)/1000/2023
Date : 17/10/2023

To,
Principal,
Podar International School,
Plot No.30, Sector-36,
Near HP Petrol Pump,
Palm Beach Road, Nerul,
Navi Mumbai – 400 706.

Sub : Certificate of "Safe Drinking Water"
Ref : Your letter dated - 10/10/2023.

Sir,

Vide your above referred letter, you have sought Certificate of "Safe Drinking Water"
This is to inform you that N.M.M.C. Supplies water to ANANDILAL & GANESH PODAR
SOCIETY, Nerul, vide Consumer No.201703539(IU-36076) and Consumer No.200902006
(IV-36034) Plot No.30, Sector-36, Loc-Karave GES, Belapur Ward, Navi Mumbai.

We here by Certify that the Supplied water from Navi Mumbai Municipal Corporation is
safe for drinking.



17/10/23
Executive Engineer(Belapur)
Navi Mumbai Municipal Corporation

[Handwritten signature]

Sehatarjee
PRINCIPAL

Podar International School (CBSE),
Seawoods, Nerul (W), Navi Mumbai

NAVI MUMBAI MUNICIPAL CORPORATION

ENVIRONMENT LABORATORY

Below Agrol Bridge, sector 11, C.B.D. Belapur, Navi Mumbai - 400 614.
Tel.: 022-2757 9882

Laboratory Reference No.: 80
Date: 4/10/23

Location of Sampling : Podar International School
Time of Sampling : Sec-36, Plot NO-30, Nerul (W)
Navi Mumbai - 400 706
Parameter : PH, Turbidity, Res. Cl
Bacteriological testing : MPN (E-coli / F-coli)
Analysis Charges : RS:- 1050/-

Sr. No.	Water Quality Testing Parameter	Quantity of Sample		Charges in Rs.
		Volume, ml	Number	
1.	pH	300ml	6	150
2.	Electronic Conductivity			-
3.	Turbidity			150
4.	Dissolved Oxygen			
5.	Suspended Solids			
6.	Total Dissolved Solids			
7.	Total Solids			
8.	Acidity			
9.	Alkalinity			
10.	Chlorides			
11.	Residual Chlorine			150
12.	Total Coliform / Fecal Coliform			600
13.	Sulphate			
14.	Phosphate			
15.	Calcium			
16.	Total Hardness			
17.	B.O.D.			
18.	C.O.D.			
19.	Nitrite			
20.	Nitrate			
21.	Kjeldhal Nitrogen			
22.	Sulphides			
23.	Oil and Grease			
			Total in Rs.	1050/-

Remark: for checking potability of drinking water.

Slip Prepared by:-

Samples:-

- 1) 'O' Bldg - 2nd floor water cooler (I.C.S.E)
- 2) 'O' Bldg - Water Tank
- 3) 'N' Bldg - 8th floor water cooler (C)
- 4) 'N' Bldg - Water Tank
- 5) Podar Prep Nerul - Tap water
- 6) Podar Prep - Aqua Guard.

Shatterjee
PRINCIPAL

Podar International School (CBSE),
Seawoods, Nerul (W), Navi Mumbai





नवी मुंबई
महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अप्रोव्ही पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/80/2023-2024

Date : 04/10/2023

Date of sample received. : 04/10/2023

Date of sample testing : 04/10/2023 to 06/10/2023

Customer's Name and Location : Podar International School
Sector - 36, Plot No. 30
Nerul (W)
Navi Mumbai 400 706

TEST REPORT

Sr. No.	Testing Parameter	pH	Turbidity	Residual Chlorine	Total Coliforms	E. Coli	F. Coli
	Test Standards (IS 10500 : 2012)	6.5 - 8.5	Max. 5.0 N.T.U.	Min. 0.2 mg/l	0 per 100 ml	-ve	-ve
1)	'O' Bldg 2 nd Floor Cooler (ICSE)	7.3	0.2	0.0	0	-ve	-ve
2)	'O' Bldg Water Tank	7.1	0.1	0.3	0	-ve	-ve
3)	'N' Bldg 5 th Floor Cooler (CBSE)	7.0	0.1	0.0	0	-ve	-ve
4)	'N' Bldg Water Tank	7.0	0.1	0.0	0	-ve	-ve
5)	Podar Prep Nerul - Tap Water	7.0	0.1	0.0	0	-ve	-ve
6)	Podar Prep - Aqua Guard	7.0	0.1	0.0	0	-ve	-ve

Test Report No. : 80

Date : 06/10/2023

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.
Podar International School (CBSE),
Seawoods, Nerul (W), Navi Mumbai



Schatterjee
PRINCIPAL

Lab Incharge

Shadi

Lab Chemist

For Staff

Environment Laboratory