

Maharashtra State public Health Service

District Public Health Laboratory, Sangli

Email - sanglidphl@gmail.com Phone 0233 2310652

REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

To ~~Sr. Admin Manager, Podar International School & Junior College, Vishrambag-Kupwad MIDC Road, Sangli~~

With reference to letter No. & Date NIL 25/04/2023

Laboratory Reference No. 3-256-15

Date of Sample Collection 25/04/2023

Date of Sample Receipt 25/04/2023

Date of Examination Started 25/04/2023

Sr. No.	Details of Sample	Examination Results		Remark
		Probable Number of Micro organisms/100ml sample		
		Coliforms	Thermotolerant Coliforms	
1	RO Water - Podar International School & Junior College, Sangli	0	—	Water Sample is potable bacteriologically.

Remark - Nonpotable water can be used for drinking purposes after proper chlorination and with confirmation of sample is retested for bacteriological examination and found potable.


Report No. 862/2023

Date 28 APR 2023

Receipt No- 7591677

Amount- 340

Date- 25 April 2022

  
J.R. SCIENTIFIC OFFICER  
Dist. Public Health Laboratory,  
Sangli.