

PROFORMA REGARDING SAFE DRINKING WATER AND SAINTARY CONDITION
CERTIFICATE

No. _____

Date 24/12/2020

It is certified that an inspection team headed by Dr. Anil Sukhdeo Gir
Medical Officer, Primary Health Centre, Chadbala (Name of Officer
with designation) from PHC Chadbala (Name of
department/Office) inspected the
Vadgaon Maval Potdar School (Name & Address of
the school) on 8/12/2020 and found that the as same above
(Name of school) has

adequate drinking water facilities for the students and members of staff of the institution and
is maintaining the hygienic sanitation condition in the school building & the campus as per the
standards prescribed by the central/state/U T Govt.
Water sample of drinking water is safe for drinking.
The above valid for a period of _____



Signature with Seal _____
Name I/C Medical Officer
Designation PHC Khadbala
Tal. Maval, Dist. Pune

Potdar International School
& NB 103/2, Plot B
Vadgaon Maval, Pune
(Name & Address of the institution)



DSJ FRANKLIN
General Manager - Pune Region

Theressa
Principal 2021
Podar International School
Vadgaon (Maval), Dist. Pune



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

No-WS/Lab/291/2020


Date - 11/12/2020

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME - Potdar International School DATE OF EXAMINATION - 8/12/2020

ADDRESS - Talegaon

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN / 100ml		REMARKS
			Coliforms	E. Coli	
1	water sample	nil	0/100 ml	-	potable
2	/				
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					


ANALYST
 W.P. Lab. No. 291/2020
 No. 11/12/2020


 08/12/2020
 Principal
 Podar International School
 Vadgaon (Maval), Dist. Pune


DSJ FRANKLIN
 General Manager - Pune Region



PIMPRI CHINCHWAD MUNICIPAL CORPORATION (W/S) DIVISION



Report Of Chemical Examination Of Water

NO-WS-LAB/290/2020

DATE - 10/12/2020

NAME - Podar International School

DATE OF RECEIPT - 08/12/2020

ADDRESS - Talegaon

DATE OF EXAMINATION - 10/12/2020

SOURCE - R.O water

No.	Tests	I. S Standard for Drinking Water	Results mg/lit	Results mg/lit	Conclusion
1	Turbidity	5 N.T.U max	0.63 NTU		
2	pH	6.5 to 8.5	7.56		
3	Total Hardness (AS CaCo3)	300 mg/lit max	52 mg/lit		
4	Chloride	250 mg/lit max	16 mg/lit		
5	Calcium	75 mg/lit max	8.01 mg/lit		

NOTE-SAMPLE NOT DRAWN BY THIS LABORATORY

COPY TO-

DSJ FRANKLIN
General Manager - Pune Region



04/06/2021
Principal
Podar International School
Vadgaon, Maharashtra